



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 15, 2010

**Re:** Guernsey County  
Couto's Pizza and Subs  
Self-Monitoring Report Violations  
NPDES Permit #0PR00099\*CD  
Correspondence (PWW)

Mr. Larry Couto  
P.O. Box 313  
Buffalo, Ohio 43722

Dear Mr. Couto:

We have received your self-monitoring reports covering the months of May through July 2010 for Couto's Pizza and Subs wastewater treatment facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	13.	7/1/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.91	7/1/2010
001	80082	CBOD 5 day	30D Conc	10	15.	7/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	2.3	2.91	7/14/2010

\* 30D Conc is equal to the average monthly concentration limit.  
1 D Conc is equal to the maximum daily concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/mlm

C: Matt Stiers, Operator