



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

November 24, 2010

Re: Guernsey County
Couto's Pizza and Subs
Self-Monitoring Report Violations
NPDES Permit #0PR00099*CD
Correspondence (PWW)

Mr. Larry Couto
P.O. Box 313
Buffalo, Ohio 43722

Dear Mr. Couto:

We have received your self-monitoring reports covering the months of August through October 2010 for Couto's Pizza and Subs wastewater treatment facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.49	8/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	2.3	2.49	8/4/2010

* 30D Conc is equal to the average monthly concentration limit.

1 D Conc is equal to the maximum daily concentration limit.

Please submit within **10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator