



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 1, 2009

Re: Guernsey County
Coventry Estates II Subdivision WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPG00043*ED
Correspondence (PWW)

Guernsey County Board of Commissioners
627 Wheeling Avenue, Suite 300
Cambridge, Ohio 43725-2251

Dear Board of Commissioners:

We have received your self-monitoring reports covering the months of May through August 2009 for the Coventry Estates II Subdivision's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	1100.	6/1/2009
August 2009:						
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3	3.7	8/8/2009

* 7D Conc is equal to the average weekly concentration limit.
30D Conc is equal to the average monthly concentration limit.

Please submit within **10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Dennis Dougherty, Operator, Guernsey Co. Water and Sewer Department