



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 1, 2009

**Re: Guernsey County
Buckeye Trail Schools WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PT00012*AD
Correspondence (PWW)**

Mr. Lonnie Caudill, Principal
Buckeye Trail Middle School
65555 Wintergreen Road
Lore City, Ohio 43755

Dear Mr. Caudill:

We have received your self-monitoring reports covering the months of May through August 2009 for the Buckeye Trail Jr. & Sr. High School's WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.03	5/1/2009
June 2009:						
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	5.66	6/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.7074	6/1/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.11	.13154	6/1/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	2.81	6/8/2009

*1 D Conc is equal to the maximum daily concentration limit.
1 D Qty is equal to average weekly loading limit.
30 D Conc is equal to average monthly concentration limit.

Please submit within **10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response to these violations has already been sent no further documentation is needed.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Paul Fields, Operator, Cambridge Water Pollution Control Center