



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 15, 2010

**Re:** Guernsey County  
Go Mart No. 57 WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PR00089\*BD  
Correspondence (PWW)

Mr. Mike Conant  
Go Mart, Inc.  
64322 Wintergreen Road  
Lore City, Ohio 43755

Dear Mr. Conant:

We have received your self-monitoring reports covering the months of May through July 2010 for the Go Mart No. 57 wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.81	5/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	1.81	5/3/2010
<b>June 2010</b>						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	38.	6/1/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.019	.32362	6/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	38.	6/7/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.028	.32362	6/7/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	6/7/2010
<b>July 2010</b>						
001	31616	Fecal Coliform	30D Conc	1000	1700.	7/1/2010

\* 1D Conc is equal to the maximum daily concentration limit.  
1D Qty is equal to the maximum daily loading limit.  
30D Conc is equal to the average monthly concentration limit.  
30D Qty is equal to the average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is necessary.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/mlm

c: Matt Stiers, Operator