



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 19, 2008

**Re: Guernsey County
Lake Seneca Resorts WWTP
Self-Monitoring Report Violations
NPDES Permit #OPX00003*DD
Correspondence (PWW)**

Lake Seneca Resorts Association
c/o Lake Seneca Resorts Trustees
17875 Lashley Road
Senecaville, Ohio 43780

Dear Trustees:

We have received your self-monitoring reports covering the months of July through December 2007 for the Lake Seneca Resort's wastewater treatment facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.50	4.065	7/1/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.25	6.02	7/1/2007
001	00300	Dissolved Oxygen	1D Conc	6.0	5.	7/4/2007
001	80082	CBOD 5 day	7D Conc	12	16.	7/8/2007
001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	7/17/2007
August 2007						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.50	2.94333	8/1/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.25	8.6	8/1/2007
001	31616	Fecal Coliform	7D Conc	2000	8900.	8/1/2007
001	31616	Fecal Coliform	30D Conc	1000	3529.87	8/1/2007


*1 D Conc is equal to the maximum daily concentration limit.
7D Conc is equal to the average weekly concentration limit.
30D Conc is equal to the average monthly concentration limit.
30D Qty is equal to the average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Lake Seneca Resorts WWTP
Page 2

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator