



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 15, 2010

**Re: Guernsey County
Lake Seneca Resorts WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PX00003*ED
Correspondence (PWW)**

Lake Seneca Resorts Association
c/o Lake Seneca Resorts Trustees
17875 Lashley Road
Senecaville, Ohio 43780

Dear Trustees:

We have received your self-monitoring reports covering the months of May through July 2010 for the Lake Seneca Resorts wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	2.81667	5/1/2010
001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.25	5.83	5/11/2010
001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.25	2.62	5/25/2010
June 2010						
001	00530	Total Suspended Solids	1D Conc	18	25.	6/1/2010
001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	7.225	6/1/2010
001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.17	.21551	6/1/2010
001	80082	CBOD 5 day	1D Conc	12	30.	6/1/2010
001	80082	CBOD 5 day	30D Conc	8	11.25	6/1/2010
001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.25	4.77	6/8/2010
001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.25	9.68	6/22/2010
July 2010						
001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	7/27/2010

* 1D Conc is equal to a maximum daily concentration limit.
30D Conc is equal to a monthly average concentration limit.
30D Qty is equal to the monthly average loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/mlm

c: Matt Stiers, Operator