



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Kortesi, Director

May 14, 2008

**Re: Guernsey County  
Langley-Lew Mobile Home Park  
Self-Monitoring Report Violations  
NPDES Permit #0PV00524\*AD  
Correspondence (PWW)**

Mr. Willie Langley  
6180 Fairdale Drive  
Cambridge, Ohio 43725

Dear Mr. Langley:

We have received your self-monitoring reports covering the months of October 2007 through March 2008 for the Langley-Lew MHP, formerly known as the Pine View MHP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	21.6	10/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.017	.22074	10/1/2007
001	80082	CBOD 5 day	30D Qty	0.11	.40878	10/1/2007
001	80082	CBOD 5 day	30D Conc	10	40.	10/1/2007
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	10/7/2007
001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	10/8/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.3	21.6	10/8/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.026	.22074	10/8/2007
001	80082	CBOD 5 day	7D Conc	15	40.	10/8/2007
001	80082	CBOD 5 day	7D Qty	0.17	.40878	10/8/2007
001	00300	Dissolved Oxygen	1D Conc	5.0	3.8	10/22/2007
001	50060	Chlorine, Total Residual	1D Conc	0.019	.3	10/22/2007
001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	11/19/2007
001	00300	Dissolved Oxygen	1D Conc	5.0	2.2	12/17/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.040	.06847	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.5	6.7	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	5.3	6.7	2/15/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.060	.06847	2/15/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.040	.05825	3/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.5	5.7	3/1/2008


- \*1 D Conc is equal to the maximum daily concentration limit.
- 7D Conc is equal to the average weekly concentration limit.
- 7D Qty is equal to the average weekly loading limit.
- 30D Conc is equal to the average monthly concentration limit.
- 30D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

As discussed earlier, you have been gathering excess effluent data and working with a consultant to design a new wastewater treatment plant. As you are aware the current treatment plant provides inadequate treatment and upgrades will be necessary to maintain compliance to your permit. Please provide an update of your progress to design a new treatment plant and a schedule as to when a PTI will be submitted for the approval of a new system.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Guernsey County Health Department