



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 5, 2008

Re: Guernsey County
Langley-Lew Mobile Home Park
Self-Monitoring Report Violations
NPDES Permit #0PV00524*AD
Correspondence (PWW)

Mr. Willie Langley
819 Lakeside Drive
Cambridge, Ohio 43725

Dear Mr. Langley:

We have received your self-monitoring reports covering the months of August through October 2008 for the Langley-Lew MHP, formerly known as the Pine View MHP. Our review indicates an October MOR was not submitted, as well as other violations to your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

| Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|-----------------------|----------------|------------------------|------------|-------|----------------|----------------|
| 001 | 00300 | Dissolved Oxygen | 1D Conc | 5.0 | 4.1 | 8/4/2008 |
| 001 | 00300 | Dissolved Oxygen | 1D Conc | 5.0 | 4.1 | 8/18/2008 |
| 001 | 50060 | Chlorine, Total Residu | 1D Conc | 0.019 | .3 | 8/20/2008 |
| September 2008 | | | | | | |
| 001 | 00530 | Total Suspended Solids | 30D Conc | 12 | 18. | 9/1/2008 |
| 001 | 00530 | Total Suspended Solids | 30D Qty | 0.14 | .16351 | 9/1/2008 |
| 001 | 00610 | Nitrogen, Ammonia (NH3 | 30D Conc | 1.5 | 7.4 | 9/1/2008 |
| 001 | 00610 | Nitrogen, Ammonia (NH3 | 7D Conc | 2.3 | 7.4 | 9/1/2008 |
| 001 | 00610 | Nitrogen, Ammonia (NH3 | 30D Qty | 0.017 | .06722 | 9/1/2008 |
| 001 | 00610 | Nitrogen, Ammonia (NH3 | 7D Qty | 0.026 | .06722 | 9/1/2008 |
| 001 | 80082 | CBOD 5 day | 30D Conc | 10 | 20. | 9/1/2008 |
| 001 | 80082 | CBOD 5 day | 7D Conc | 15 | 20. | 9/1/2008 |
| 001 | 80082 | CBOD 5 day | 30D Qty | 0.11 | .18168 | 9/1/2008 |
| 001 | 80082 | CBOD 5 day | 7D Qty | 0.17 | .18168 | 9/1/2008 |
| 001 | 00300 | Dissolved Oxygen | 1D Conc | 5.0 | 4.6 | 9/2/2008 |
| 001 | 31616 | Fecal Coliform | 7D Conc | 2000 | 12333. | 9/15/2008 |
| 001 | 00300 | Dissolved Oxygen | 1D Conc | 5.0 | 4. | 9/16/2008 |

* 1 D Conc is equal to the maximum daily concentration limit.
7D Conc is equal to the average weekly concentration limit.
7D Qty is equal to the average weekly loading limit.
30D Conc is equal to the average monthly concentration limit.
30D Qty is equal to the average monthly loading limit.


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

A response to my last violation letter described actions you were taking to minimize flow to the plant by eliminating connections. Please provide an update on the progress to eliminate some existing connections since the current plant is not adequate to provide treatment at the current waste flows without major improvements. Failure to significantly reduce the flow to the wastewater treatment plant will require significant upgrades to the plant to maintain compliance. This letter also serves as a reminder that your NPDES renewal application is due to this office on January 1, 2009.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. A monthly report for October shall also be submitted to our Columbus office. If the monthly operating reports are submitted via hardcopy on the 4500 forms they are to be submitted to our Columbus office by the 15th day of the month following the month of interest.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/mlm

c: Guernsey County Health Department