



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 30, 2009

Re: Guernsey County
EACOG, Liberty Manor Facility
Self-Monitoring Report Violations
Ohio EPA Permit No. OPT00026*AD
Correspondence (PWW)

Mr. Rod Hollingsworth
Eastern Alliance Council of Governments
1205 Newark Road
Zanesville, Ohio 43701

Dear Mr. Hollingsworth:

We have received your self-monitoring reports covering the months of May through August 2009 for Liberty Manor. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	1600.	08/01/09

* 30 D Conc is equal to average monthly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Michael Wisecarver, Operator, Wisecarver Environmental Services