



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 9, 2009

Re: Guernsey County
ODOT Rest Stops 5-27 & 5-29
Self-Monitoring Report Violations
Correspondence (PWW)

Mr. Terry Gregg, Operator
ODOT, District 5
P.O. Box 306
Jacksontown, Ohio 43030

Dear Mr. Gregg:

We have received your self-monitoring reports covering the months of January through April 2009 for ODOT Rest Area's 5-27 and 5-29. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

| Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|-----------------------------|----------------|------------------------|------------|-------|----------------|----------------|
| 001 | 00530 | Total Suspended Solids | 7D Conc | 18 | 22. | 3/1/2009 |
| ODOT Rest Area 5-29: | | | | | | |
| 001 | 00530 | Total Suspended Solids | 30D Conc | 12 | 31.5 | 3/1/2009 |
| 001 | 00530 | Total Suspended Solids | 7D Conc | 18 | 63. | 3/1/2009 |
| 001 | 00530 | Total Suspended Solids | 7D Qty | 0.68 | .7869 | 3/1/2009 |

* 7 D Qty is equal to a maximum daily loading limit.
7 D Conc is equal to the maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please submit within **10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh