



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 28, 2010

**Re:** Guernsey County  
ODOT Rest Stop 5-29  
Self-Monitoring Report Violations  
Correspondence (PWW)

Mr. Terry Gregg, Operator  
ODOT, District 5  
P.O. Box 306  
Jacksontown, Ohio 43030

Dear Mr. Gregg:

We have received your self-monitoring reports covering the months of October through December 2009 for ODOT Rest Area facility number 5-29. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	44.	10/1/2009
001	00530	Total Suspended Solids	7D Conc	18	81.	10/1/2009
001	00530	Total Suspended Solids	30D Qty	0.45	.47767	10/1/2009
001	00530	Total Suspended Solids	7D Qty	0.68	.8891	10/1/2009

\* 7 D Qty is equal to a maximum daily loading limit.  
7 D Conc is equal to the maximum daily concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh