



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 25, 2010

Re: Guernsey County
ODOT Rest Stop 5-29
Self-Monitoring Report Violations
Correspondence (PWW)

Mr. Terry Gregg, Operator
ODOT, District 5
P.O. Box 306
Jacksontown, Ohio 43030

Dear Mr. Gregg:

We have received your self-monitoring reports covering the months of January through April 2010 for the ODOT Rest Area facility number 5-29. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	6.0	7.4	4/1/2010

* 7 D Conc is equal to the average weekly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh