



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 9, 2009

**Re:** Guernsey County  
ODOT Rest Stops 5-27 & 5-29  
Self-Monitoring Report Violations  
Correspondence (PWW)

Mr. Terry Gregg, Operator  
ODOT, District 5  
P.O. Box 306  
Jacksontown, Ohio 43030

Dear Mr. Gregg:

We have received your self-monitoring reports covering the months of January through April 2009 for ODOT Rest Area's 5-27 and 5-29. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Conc	18	22.	3/1/2009
<b>ODOT Rest Area 5-29:</b>						
001	00530	Total Suspended Solids	30D Conc	12	31.5	3/1/2009
001	00530	Total Suspended Solids	7D Conc	18	63.	3/1/2009
001	00530	Total Suspended Solids	7D Qty	0.68	.7869	3/1/2009

\* 7 D Qty is equal to a maximum daily loading limit.  
7 D Conc is equal to the maximum daily concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh