



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 14, 2008

Re: Guernsey County
Ports Petroleum
Self-Monitoring Report Violations
Ohio EPA Permit No. OPR00079*AD
Correspondence (PWW)

Mr. Bob Stevenson
Ports Petroleum Company, Inc.
P.O. Box 1046
Wooster, Ohio 44691

Dear Mr. Stevenson:

We have received your self-monitoring report covering the months of December through March 2008 for the Ports Petroleum wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:


Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	21.	12/1/2007
001	00530	Total Suspended Solids	7D Conc	18	21.	12/1/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	44.7	12/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	44.7	12/1/2007
001	00530	Total Suspended Solids	7D Conc	18	24.	1/1/2008
001	00530	Total Suspended Solids	30D Conc	12	24.	1/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	39.	1/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	39.	1/1/2008
001	80082	CBOD 5 day	30D Conc	10	25.	1/1/2008
001	80082	CBOD 5 day	7D Conc	15	25.	1/1/2008
001	00530	Total Suspended Solids	30D Conc	12	17.	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	5.19	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	5.19	2/1/2008
001	80082	CBOD 5 day	30D Conc	10	18.	2/1/2008
001	80082	CBOD 5 day	7D Conc	15	18.	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	14.4	3/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	14.4	3/1/2008
001	80082	CBOD 5 day	30D Conc	10	13.	3/1/2008

*7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of the violations has been sent to our office please disregard. This facility is also under a compliance schedule to install a de-chlorination system which has yet to be installed. Please provide a schedule as to when this will be completed. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator