



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 15, 2010

Re: Guernsey County
Ports Petroleum
Self-Monitoring Report Violations
Ohio EPA Permit No. OPR00079*BD
Correspondence (PWW)

Tom Moore, Director of Maintenance
Ports Petroleum Company, Inc.
P.O. Box 1046
Wooster, Ohio 44691

Dear Mr. Moore:

We have received your self-monitoring report covering the months of May through July 2010 for the Ports Petroleum wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	2.82	6/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	2.82	6/7/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	34.6	7/1/2010
001	31616	Fecal Coliform	30D Conc	1000	12200.	7/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	34.6	7/12/2010
001	31616	Fecal Coliform	1D Conc	2000	12200.	7/12/2010

*1 D Conc is equal to maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of the violations has been sent to our office please disregard. If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/mlm

c: Matt Stiers, Operator