



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

November 24, 2010

Re: Guernsey County
Ports Petroleum
Self-Monitoring Report Violations
Ohio EPA Permit No. OPR00079*BD
Correspondence (PWW)

Mr. Tom Moore, Director of Maintenance
Ports Petroleum Company, Inc.
P.O. Box 1046
Wooster, Ohio 44691

Dear Mr. Moore:

We have received your self-monitoring report covering the months of August through October 2010 for the Ports Petroleum wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	4.36	8/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	4.36	8/2/2010

*1 D Conc is equal to maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator