



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 9, 2009

Re: Guernsey County
Quaker City WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPA00003*HD
Correspondence (PWW)

Mayor and Council
Village of Quaker City
210 Smith Avenue
P.O. Box 156
Quaker City, Ohio 43773

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through April 2009 for the Quaker City wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	3.0	3.35938	1/1/2009
001	00530	Total Suspended Solids	7D Qty	14	14.9734	1/22/2009
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	4.6	6.5102	1/22/2009
001	80082	CBOD 5 day	7D Qty	12	18.8795	1/22/2009
March 2009:						
001	80082	CBOD 5 day	30D Conc	25	27.25	3/1/2009

- * 7D Conc is equal to a weekly average concentration limit.
- 7 D Qty is equal to the weekly average loading limit.
- 30D Conc is equal to the monthly average concentration limit.
- 30D Qty is equal to the monthly average concentration loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response to these violations has been sent no additional information is requested at this time.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Eric Phillips, Operator, Envirotech Environmental