



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 15, 2010

Re: Guernsey County
Quaker City WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PA00003*HD
Correspondence (PWW)

Mayor and Council
Village of Quaker City
210 Smith Avenue
P.O. Box 156
Quaker City, Ohio 43773

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of May through July 2010 for the Quaker City wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:


Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	20	31.5	5/1/2010
001	00530	Total Suspended Solids	30D Qty	6	13.7764	5/1/2010
001	00530	Total Suspended Solids	7D Conc	30	54.	5/8/2010
001	00530	Total Suspended Solids	7D Qty	9	34.3375	5/8/2010
001	80082	CBOD 5 day	7D Qty	6	13.3534	5/8/2010
001	00530	Total Suspended Solids	7D Conc	30	35.	5/15/2010
001	00530	Total Suspended Solids	7D Qty	9	14.4397	5/15/2010
June 2010						
001	00530	Total Suspended Solids	30D Conc	20	26.2	6/1/2010
001	00530	Total Suspended Solids	30D Qty	6	10.7070	6/1/2010
001	00530	Total Suspended Solids	7D Conc	30	36.	6/8/2010
001	00530	Total Suspended Solids	7D Qty	9	19.3489	6/8/2010
001	00530	Total Suspended Solids	7D Conc	30	45.	6/15/2010
001	00530	Total Suspended Solids	7D Qty	9	20.3481	6/22/2010
July 2010						
001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	2.5	7/1/2010
001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.5	.55587	7/1/2010
001	00610	Nitrogen, Ammonia (NH3	7D Conc	2.25	3.12	7/8/2010
001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.7	.72036	7/8/2010

* 7D Conc is equal to the weekly average concentration limit.
7D Qty is equal to the weekly average loading limit.
30D Conc is equal to the monthly average concentration limit.
30D Qty is equal to the monthly average loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of the violations has been sent to our office, no further documentation is required.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/mlm

c: Eric Phillips, Operator, Envirotech Environmental