



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 24, 2010

**Re:** Guernsey County  
Quaker City WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PA00003\*HD  
Correspondence (PWW)

Mayor and Council  
Village of Quaker City  
210 Smith Avenue  
P.O. Box 156  
Quaker City, Ohio 43773

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of August through October 2010 for the Quaker City wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	20	27.5	8/1/2010
001	00530	Total Suspended Solids	7D Conc	30	73	8/8/2010
001	00530	Total Suspended Solids	7D Qty	9	12.1574	8/8/2010

\* 7D Conc is equal to the weekly average concentration limit.  
7D Qty is equal to the weekly average loading limit.  
30D Conc is equal to the monthly average concentration limit.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Eric Phillips, Operator, Envirotech Environmental