



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-6501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 19, 2008

Re: Hocking County
Enterprise Elementary School
Self-Monitoring Report Violations
Ohio EPA Permit No. OPT00028*BD
Correspondence (PWW)

Ms. Kathy Krumlauf
Logan-Hocking Board of Education
121 South Spring Street
Logan, Ohio 43138

Dear Ms. Krumlauf:

We have reviewed your self-monitoring reports covering the months of June through December 2007 for the Enterprise Elementary Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	1967.	9/1/2007
001	31616	Fecal Coliform	30D Conc	1000	7000.	10/1/2007
001	00530	Total Suspended Solids	30D Conc	12	14.	10/1/2007
001	31616	Fecal Coliform	7D Conc	2000	7000.	10/8/2007
001	00530	Total Suspended Solids	30D Conc	12	67.	12/1/2007
001	00530	Total Suspended Solids	30D Qty	.16	.1902	12/1/2007
001	00530	Total Suspended Solids	7D Conc	18	67.	12/8/2007


* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,

A handwritten signature in cursive script, appearing to read "Jack Knapp".

Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Keith Brown, Operator