



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 10, 2009

Re: Hocking County
Green Elementary School
WWTP Inspection
Correspondence (PWW)

Mr. Keith Brown, Operator
Logan-Hocking Board of Education
121 South Spring Street
Logan, Ohio 43138

Dear Mr. Brown:

On May 21, 2009, I conducted an inspection of the Green Elementary School wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPT00038*BD. A copy of the inspection report is attached.


As a part of the inspection, we have reviewed your self-monitoring reports from January 1 to May 1, 2009 for the Green Elementary WWTP. Our review indicates the plant has violated the Total Suspended Solids limit several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	15.	2/1/2009
001	00530	Total Suspended Solids	30D Qty	.11	.15443	2/1/2009
001	00530	Total Suspended Solids	30D Conc	12	20.	3/1/2009
001	00530	Total Suspended Solids	7D Conc	18	20.	3/8/2009
001	00530	Total Suspended Solids	30D Qty	.11	.20061	3/1/2009
001	00530	Total Suspended Solids	7D Qty	.17	.20061	3/8/2009
001	00530	Total Suspended Solids	30D Conc	12	28.	4/1/2009
001	00530	Total Suspended Solids	7D Conc	18	28.	4/15/2009
001	00530	Total Suspended Solids	30D Qty	.11	.29039	4/1/2009
001	00530	Total Suspended Solids	7D Qty	.17	.29039	4/15/2009

* 30 D Conc is equal to average monthly concentration limit.

Please provide a written response within 30 days upon receipt of this letter and explain why these violations occurred and explain what will be done to prevent further noncompliance. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Stephen Stirn, Supt., Logan-Hocking Board of Education

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00038*BD	OH0115169	May 21, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Green Elementary School 15663 State Route 595 Logan, Ohio 43138	1:30 p.m.	August 1, 2008
	Exit Time	Permit Expiration Date
	1:50 p.m.	July 31, 2009

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Keith Brown, Director of Facilities	(740) 385-8247
Name, Address and Title of Responsible Official	Phone Number
Logan-Hocking Board of Education 121 S. Spring Street Logan, Ohio 43138	(740) 385-8247

C. AREAS EVALUATED DURING INSPECTION

<u> </u> S Permit	<u> </u> N Flow Measurement	<u> </u> N/A Pretreatment
<u> </u> N Records/Reports	<u> </u> N/A Laboratory	<u> </u> S Compliance Schedules
<u> </u> S Operations & Maintenance	<u> </u> S Effluent/Receiving Waters	<u> </u> S Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> S Sludge Storage/Disposal	<u> </u> Other
<u> </u> N/A Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

Please see attached letter.



Jack Knapp, Inspector, Ohio EPA, Southeast District Office

6/10/09

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

6/11/09

Date