



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 19, 2008

Re: Hocking County
Haydenville WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPG00062*CD
Correspondence (PWW)

Hocking County Commissioners
1 E. Main Street
Logan, Ohio 43138

Dear Board of Commissioners:

We have reviewed your self-monitoring reports covering the months of June through December 2007 for the Haydenville Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00300	Dissolved Oxygen	1D Conc	5	4.	6/4/2007
001	00300	Dissolved Oxygen	1D Conc	5	4.	6/18/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.3	6/25/2007
001	31616	Fecal Coliform	30D Conc	1000	9600.	7/1/2007
001	31616	Fecal Coliform	7D Conc	2000	9600.	7/1/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.7	7/2/2007
001	00300	Dissolved Oxygen	1D Conc	5	1.6	7/9/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.3	7/16/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.7	7/23/2007
001	00300	Dissolved Oxygen	1D Conc	5	1.9	7/30/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.3	9/4/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.6	9/10/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.1	9/17/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.5	9/24/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.6	10/1/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.9	10/9/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.9	10/15/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.7	10/22/2007
001	00300	Dissolved Oxygen	1D Conc	5	4.2	10/29/2007

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	66.	11/1/2007
001	00530	Total Suspended Solids	30D Qty	2.55	6.49506	11/1/2007
001	80082	CBOD 5 day	30D Conc	25	38.	11/1/2007
001	80082	CBOD 5 day	30D Qty	2.13	3.73958	11/1/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.6	11/5/2007
001	00300	Dissolved Oxygen	1D Conc	5	4.1	11/13/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.9	11/19/2007
001	00530	Total Suspended Solids	7D Conc	45	66.	11/22/2007
001	00530	Total Suspended Solids	7D Qty	3.83	6.49506	11/22/2007
001	80082	CBOD 5 day	7D Qty	3.41	3.73958	11/22/2007
001	00300	Dissolved Oxygen	1D Conc	5	4.7	11/26/2007
001	00530	Total Suspended Solids	30D Conc	30	56.	12/1/2007
001	00530	Total Suspended Solids	30D Qty	2.55	7.4186	12/1/2007
001	80082	CBOD 5 day	30D Conc	25	27.	12/1/2007
001	80082	CBOD 5 day	30D Qty	2.13	3.57683	12/1/2007
001	00300	Dissolved Oxygen	1D Conc	5	2.6	12/3/2007
001	00530	Total Suspended Solids	7D Conc	45	56.	12/15/2007
001	00530	Total Suspended Solids	7D Qty	3.83	7.4186	12/15/2007
001	80082	CBOD 5 day	7D Qty	3.41	3.57683	12/15/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.6	12/24/2007
001	00300	Dissolved Oxygen	1D Conc	5	3.1	12/31/2007


- * 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Dan Bauman, Operator