



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 5, 2010

**Re: Hocking County  
Hocking Hills Elementary  
WTP Inspection  
Correspondence (PWW)**

Mr. Keith Brown  
Logan-Hocking Board of Education  
2019 E. Front Street  
Logan, Ohio 43138

Dear Mr. Brown:

On March 22, 2010, I conducted an inspection of the Hocking Hills Elementary Water Treatment Plant (WTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OIY00101\*BD. A copy of the inspection report is attached.

As a part of the inspection, we have reviewed your self-monitoring reports from March 1, 2009 to March 1, 2010 for the Hocking Hills Elementary WTP. Our review indicates the plant violated TSS and Suspended Iron several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	45.	3/1/2009
001	01044	Iron, Suspended (Fe)	30D Conc	1000	2802.	3/1/2009
001	01044	Iron, Suspended (Fe)	1D Conc	2000	2802.	3/10/2009
001	00530	Total Suspended Solids	30D Conc	30	39.	12/1/2009
001	01044	Iron, Suspended (Fe)	30D Conc	1000	2640.	12/1/2009
001	01044	Iron, Suspended (Fe)	1D Conc	2000	2640.	12/22/2009

Please provide a written response to these comments within 30 days upon receipt describing how the above items will be addressed. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,

Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

Enclosure

c: Stephen Stirn, Logan-Hocking Board of Education