



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 13, 2009

Re: Hocking County
Lake Moor Estates
OPG00007*HD
WWTP Inspection
Correspondence (PWW)

Mr. John Perry, Operator
Lake Moor Estates WWTP
1 E. Main Street
Logan, Ohio 43138

Dear Mr. Perry:

On February 10, 2009, I conducted an inspection of the Lake Moor Estates wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPG00007*HD. A copy of the inspection report is attached.

If there are any questions, please call me at (740) 380-5268.

Sincerely,

Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure

c: Hocking County Commissioners

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPG00007*HD	OH0050237	February 10, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Lake Moor Estates WWTP Blosser Road Logan, Ohio 43138	11:00 a.m.	March 1, 2007
	Exit Time	Permit Expiration Date
	11:30 a.m.	February 29, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
John Perry, Operator	(740) 380-2613
Name, Address and Title of Responsible Official	Phone Number
Hocking County Commissioners 1 E. Main Street Logan, Ohio 43138	(740) 385-5195

C. AREAS EVALUATED DURING INSPECTION

<u> </u> S Permit	<u> </u> S Flow Measurement	<u> </u> N/A Pretreatment
<u> </u> S Records/Reports	<u> </u> N/A Laboratory	<u> </u> S Compliance Schedules
<u> </u> S Operations & Maintenance	<u> </u> S Effluent/Receiving Waters	<u> </u> S Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> S Sludge Storage/Disposal	<u> </u> Other
<u> </u> S Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



Jack Knapp, Inspector, Ohio EPA, Southeast District Office

3/19/09

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/19/09

Date