



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 28, 2010

Re: Hocking County
Laurelville WWTP
0PA00013*FD
WWTP Inspection
Correspondence (PWW)

Mayor and Council
Village of Laurelville
P.O. Box 393
Laurelville, Ohio 43135

Dear Mayor and Council:

On May 10, 2010, I conducted an inspection of the Village of Laurelville wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number 0PA00013*FD. A copy of the inspection report is attached.

The marginal rating given for the collection system is due to the excessive amount of Inflow/Infiltration (I/I) in the collection system. The village should continue to work on eliminating sources of I/I. If there are any questions, please call me at (740) 380-5268.

Sincerely,

Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure

c: Joe King, Operator

NPDES Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PA00013*FD	OH0050784	May 10, 2010	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Laurelville WWTP 16111 Creamery Hill Road Laurelville, Ohio 43135	1:40 p.m.	August 1, 2006
	Exit Time	Permit Expiration Date
	2:10 p.m.	July 31, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Joe King, Operator	(740) 642-5769
Name, Address and Title of Responsible Official	Phone Number
Mayor Village of Laurelville P.O. Box 393 Laurelville, Ohio 43135	(740) 332-9101

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N*</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>M</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


*Most of the lab work is done at the Circleville WWTP.



 Jack Knapp, Inspector, Ohio EPA, Southeast District Office

5/20/10

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

6/9/10

 Date