



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6499
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

October 8, 2008

Re: Hocking County
Laurelville WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PA00013*FD
Correspondence (PWW)

Mr. Joe King, Operator
16111 Creamery Hill Road
Laurelville, Ohio 43135

Dear Mr. King:

We have reviewed your self-monitoring reports covering the months of January through July 2008 for the Laurelville Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	19.375	2/1/2008
001	00530	Total Suspended Solids	7D Conc	18	18.5	2/8/2008
001	00530	Total Suspended Solids	7D Conc	18	23.	2/15/2008
001	00530	Total Suspended Solids	7D Conc	18	25.5	2/22/2008
001	00530	Total Suspended Solids	30D Conc	12	23.375	3/1/2008
001	00530	Total Suspended Solids	7D Conc	18	32.	3/1/2008
001	00530	Total Suspended Solids	30D Qty	9.1	25.8756	3/1/2008
001	00530	Total Suspended Solids	7D Qty	13.6	36.8886	3/1/2008
001	80082	CBOD 5 day	30D Qty	7.6	7.74735	3/1/2008
001	00530	Total Suspended Solids	7D Conc	18	25.	3/8/2008
001	00530	Total Suspended Solids	7D Qty	13.6	1.6123	3/8/2008
001	00530	Total Suspended Solids	7D Conc	18	24.	3/15/2008
001	00530	Total Suspended Solids	7D Qty	13.6	31.3852	3/15/2008
001	00530	Total Suspended Solids	7D Qty	13.6	13.6165	3/22/2008
001	00300	Dissolved Oxygen	1D Conc	5	4.91	4/7/2008
001	00300	Dissolved Oxygen	1D Conc	5	4.7	4/8/2008
001	00300	Dissolved Oxygen	1D Conc	5	4.58	4/9/2008
001	00300	Dissolved Oxygen	1D Conc	5	4.72	4/28/2008
001	00300	Dissolved Oxygen	1D Conc	5	4.56	4/29/2008
001	00300	Dissolved Oxygen	1D Conc	5	4.64	4/30/2008
001	00300	Dissolved Oxygen	1D Conc	5	4.81	5/1/2008

* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Mayor, Village of Laurelville