



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 5, 2010

**Re:** Hocking County  
Old Man's Cave Chalets  
WWTP Inspection  
Correspondence (PWW)

Mr. Mark Devol, Owner  
Old Man's Cave Chalets, Inc.  
18905 State Route 664  
Logan, Ohio 43138

Dear Mr. Devol:


On March 22, 2010, I conducted an inspection of the wastewater treatment plant (WWTP) serving Old Man's Cave Chalets. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPR00114\*CD. A copy of the inspection report is attached.

As a part of the inspection, we have reviewed your self-monitoring reports from March 1, 2009 to March 1, 2010 for the Old Man's Cave Chalets WWTP. Our review indicates the plant violated NH<sub>3</sub> several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	36.9	3/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0284	.27933	3/1/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	36.9	3/25/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.0426	.27933	3/25/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	8.4	4/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0284	.05087	4/1/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	8.4	4/21/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.0426	.05087	4/21/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	15.	8/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0094	.04542	8/1/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	15.	8/27/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.0142	.04542	8/27/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	4.49	12/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0284	.03399	12/1/2009

Please provide a written response to these comments within 30 days upon receipt describing how the above items will be addressed. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

Enclosure