



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 8, 2008

**Re:** Hocking County  
Old Man's Cave Chalets  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PR00114\*BD  
Correspondence (PWW)

Mr. Mark Devol, Owner  
Old Man's Cave Chalets  
18905 State Route 664  
Logan, Ohio 43138

Dear Mr. Devol:

We have reviewed your self-monitoring reports covering the months of January through August 2008 for the Old Man's Cave Chalets Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3	35.	1/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	35.	1/22/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3	29.8	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	29.8	2/22/2008
001	00530	Total Suspended Solids	30D Conc	12	14.	6/1/2008
001	00530	Total Suspended Solids	30D Qty	0.11	.12112	7/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1	15.	7/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.01	.18168	7/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	15.	7/22/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.014	.18168	7/22/2008
001	00300	Dissolved Oxygen	1D Conc	6	3.4	8/7/2008

\* 7 D Conc is equal to average weekly concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

c: Rick Verhotz, Stantec