



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kortesi, Director

February 19, 2008

Re: Hocking County
Old Man's Cave Chalets
Self-Monitoring Report Violations
Ohio EPA Permit No. OPG00114*BD
Correspondence (PWW)

Mr. Mark Devol, Owner
Old Man's Cave Chalets
18905 State Route 664
Logan, Ohio 43138

Dear Mr. Devol:

We have reviewed your self-monitoring reports covering the months of June through December 2007 for the Old Man's Cave Chalets Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00300	Dissolved Oxygen	1D Conc	6	4.68	7/19/2007
001	00300	Dissolved Oxygen	1D Conc	6	4.56	7/26/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1	1.4	8/1/2007
001	00300	Dissolved Oxygen	1D Conc	6	5.	8/9/2007
001	31616	Fecal Coliform	7D Conc	2000	5833.	8/15/2007
001	00300	Dissolved Oxygen	1D Conc	6	4.2	8/23/2007
001	00300	Dissolved Oxygen	1D Conc	6	5.1	8/30/2007
001	00300	Dissolved Oxygen	1D Conc	6	.5	9/6/2007
001	00300	Dissolved Oxygen	1D Conc	6	5.6	9/13/2007
001	50060	Chlorine, Total Residual	1D Conc	0.019	.22	9/27/2007
001	00530	Total Suspended Solids	30D Conc	12	14.	10/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1	1.46	10/1/2007
001	00300	Dissolved Oxygen	1D Conc	6	5.4	10/11/2007
001	00300	Dissolved Oxygen	1D Conc	6	3.3	10/18/2007
001	00300	Dissolved Oxygen	1D Conc	6	5.3	10/25/2007
001	00530	Total Suspended Solids	30D Conc	12	15.	11/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3	7.637	11/1/2007
001	00530	Total Suspended Solids	7D Conc	18	19.	11/15/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	14.7	11/15/2007

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1	34.	12/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3	34.	12/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.01	.02574	12/1/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	34.	12/15/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	34.	12/15/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.014	.02574	12/15/2007


* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Gary Silcott