



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 5, 2010

**Re: Hocking County
Rockbridge
WWTP Inspection
Correspondence (PWW)**

Mr. John Perry, Operator
Rockbridge WWTP
1 E. Main Street
Logan, Ohio 43138

Dear Mr. Perry:

On March 22, 2010, I conducted an inspection of the Rockbridge wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPH00014*CD. The following observations were noted during the inspection:

1. The treatment lagoons are already covered with duckweed. You should attempt to remove as much as possible to prevent anaerobic conditions in the lagoon.

As a part of the inspection, we have reviewed your self-monitoring reports from March 1, 2009 to March 1, 2010 for the Rockbridge WWTP. Our review indicates the plant violated TSS several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	35.6	4/1/2009
001	00530	Total Suspended Solids	30D Qty	3.18	3.22331	4/1/2009
001	00530	Total Suspended Solids	7D Conc	45	56.	4/8/2009
001	00530	Total Suspended Solids	7D Qty	4.77	5.60937	4/15/2009
001	00530	Total Suspended Solids	7D Qty	4.77	4.8448	4/22/2009
001	00530	Total Suspended Solids	30D Conc	30	30.5	10/1/2009
001	00530	Total Suspended Solids	30D Conc	30	42.	11/1/2009
001	00300	Dissolved Oxygen	1D Conc	5	4.9	12/17/2009

Please provide a written response to these comments within 30 days upon receipt describing how the above items will be addressed. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,

A handwritten signature in black ink, appearing to read "Jack Knapp", written in a cursive style.

Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure

c: Hocking County Commissioners

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPH00014*CD	OH0120430	March 22, 2010	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Rockbridge WWTP Troxel Buckeye Road Rockbridge, Ohio 43149	11:20 a.m.	March 1, 2007
	Exit Time	Permit Expiration Date
	11:30 a.m.	February 29, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
John Perry, Operator	(740) 380-2613
Name, Address and Title of Responsible Official	Phone Number
Hocking County Commissioners 1 E. Main Street Logan, Ohio 43138	(740) 385-5195

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N/A</u> Sludge Storage/Disposal	<u> </u> Other
<u>S</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


Please see attached letter



Jack Knapp, Inspector, Ohio EPA, Southeast District Office

4/6/10

Date



Tim M. Campbell, Supervisor, Ohio EPA, Southeast District Office

4/6/10

Date