



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kondeški, Director

April 5, 2010

Re: Hocking County
Rockbridge
WWTP Inspection
Correspondence (PWW)

Mr. John Perry, Operator
Rockbridge WWTP
1 E. Main Street
Logan, Ohio 43138

Dear Mr. Perry:

On March 22, 2010, I conducted an inspection of the Rockbridge wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPH00014*CD. The following observations were noted during the inspection:

1. The treatment lagoons are already covered with duckweed. You should attempt to remove as much as possible to prevent anaerobic conditions in the lagoon.

As a part of the inspection, we have reviewed your self-monitoring reports from March 1, 2009 to March 1, 2010 for the Rockbridge WWTP. Our review indicates the plant violated TSS several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	35.6	4/1/2009
001	00530	Total Suspended Solids	30D Qty	3.18	3.22331	4/1/2009
001	00530	Total Suspended Solids	7D Conc	45	56.	4/8/2009
001	00530	Total Suspended Solids	7D Qty	4.77	5.60937	4/15/2009
001	00530	Total Suspended Solids	7D Qty	4.77	4.8448	4/22/2009
001	00530	Total Suspended Solids	30D Conc	30	30.5	10/1/2009
001	00530	Total Suspended Solids	30D Conc	30	42.	11/1/2009
001	00300	Dissolved Oxygen	1D Conc	5	4.9	12/17/2009

Rockbridge
Page 2

Please provide a written response to these comments within 30 days upon receipt describing how the above items will be addressed. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure

c: Hocking County Commissioners