

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 21, 2011

**Re:** Hocking County  
Union Furnace Elementary School  
WWTP Inspection  
Correspondence (PWW)

Mr. Keith Brown, Operator  
Logan-Hocking Board of Education  
2019 E. Front Street  
Logan, Ohio 43138

Dear Mr. Brown:

On December 9, 2010, I conducted an inspection of the Union Furnace Elementary School wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPT00013\*CD.

As a part of the inspection, we have reviewed your self-monitoring reports from July 1, 2010 to January 1, 2011 for the Union Furnace Elementary WWTP. Our review indicates the plant violated fecal coliform. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	7030.	9/1/2010
001	31616	Fecal Coliform	7D Conc.	2000	7030.	9/8/2010

\* 30 D Conc is equal to average monthly concentration limit

Please provide a written response within 30 days upon receipt of this letter and explain why the violations occurred and explain what will be done to prevent further noncompliance. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

Enclosure

c: Stephen Stirn, Superintendent, Logan-Hocking Board of Education