



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 19, 2008

Re: Jackson County
Wellston South Water Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 01Y00081*AD
Correspondence (IWW)

Mayor Edgar Hayburn and City Council
City of Wellston
203 E. Broadway
Wellston, Ohio 45692

Dear Mayor Hayburn and Council Members:

We have received your self-monitoring reports covering the months of January through December 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Permit Limit	Reported	Date
January 2007						
001	Chlorine	1D Conc	mg/L	0.019	0.06	1/10/2007
001	Chlorine	1D Conc	mg/L	0.019	0.12	1/24/2007
March 2007						
001	Chlorine	1D Conc	mg/L	0.019	0.06	3/7/2007
001	Chlorine	1D Conc	mg/L	0.019	0.05	3/28/2007
November 2007						
001	Chlorine	1D Conc	mg/L	0.019	0.05	11/14/2007
001	Chlorine	1D Conc	mg/L	0.019	0.06	11/27/2007
December 2007						
001	Chlorine	1D Conc	mg/L	0.019	0.05	12/27/2007

- NOTES:** 1D Conc = Daily Concentration Value
 1D Qty = Daily Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Failure to report violations of the effluent limitations is also a violation of your NPDES permit. Please review Part 3 of the NPDES permit for reporting requirements.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in black ink, appearing to read 'Abbot Stevenson', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Jeff Argabright, Plant Superintendent, City of Wellston WTP
c: AS file