



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 7, 2009

**Re:** Jackson County  
Wellston South Water Treatment Plant  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 01Y00081\*AD  
Correspondence (IWW)

Mayor Edgar Hayburn and City Council  
City of Wellston  
203 E. Broadway  
Wellston, Ohio 45692

Dear Mayor Hayburn and Council Members:

We have received your self-monitoring reports covering the months of July through September 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Permit Limit	Reported	Date
<b>August 2008:</b>						
003	Total Suspended Solids	30D Conc	mg/L	30	62.2	8/1/2008
003	Total Suspended Solids	30D Qty	Kg/day	7.2	35.3	8/1/2008
003	Total Suspended Solids	1D Conc	mg/L	45	62.2	8/10/2008
003	Total Suspended Solids	1D Qty	Kg/day	10.7	35.3	8/10/2008
003	Chlorine	1D Conc	mg/L	0.019	0.05	8/10/2008
003	Total Suspended Solids	30D Conc	mg/L	30	62.2	8/1/2008

**NOTES:** 1D Conc = Daily Concentration Value  
1D Qty = Daily Loading Value  
7D Conc = Weekly Average Concentration Value  
30D Conc = Monthly Average Concentration Value  
7D Qty = Weekly Average Loading Value  
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Failure to report violations of the effluent limitations is also a violation of your NPDES permit. Please review Part 3 of the NPDES permit for reporting requirements.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

c: Jeff Argabright, Plant Superintendent, City of Wellston WTP  
c: AS file