



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-8490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 8, 2008

Re: Perry County
Ludowici Roof Tile, Inc.
Self-Monitoring Report Violations
Ohio EPA Permit #0IN00055*CD
NPDES Permit #OH0004570
Correspondence (IWW/Minor)

Mr. Brad Smith, Project Engineer II
Ludowici Roof Tile, Inc.
P.O. Box 69
New Lexington, Ohio 43764

Dear Mr. Smith:

We have received your self-monitoring reports covering the months of April through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2008:					
002	Total Suspended Solids	1D Conc	18	49.	4/1/2008
002	Total Suspended Solids	30D Conc	12	49.	4/1/2008
002	Total Suspended Solids	30D Qty	0.5	.68622	4/1/2008
002	CBOD 5 day	1D Conc	15	29.	4/1/2008
002	CBOD 5 day	30D Conc	10	29.	4/1/2008
May 2008:					
002	Total Suspended Solids	1D Conc	18	21.	5/1/2008
002	Total Suspended Solids	30D Conc	12	21.	5/1/2008
002	CBOD 5 day	1D Conc	15	16.	5/1/2008
002	CBOD 5 day	30D Conc	10	16.	5/1/2008
002	Chlorine, Total Residual	1D Conc	0.5	.63	5/1/2008

- *NOTES:** 1D Conc = Daily Average Concentration Value (mg/l)
1D Qty = Daily Average Loading Value (kg/day)
7D Conc = Weekly Average Concentration Value (mg/l)
30D Conc = Monthly Average Concentration Value (mg/l)
7D Qty = Weekly Average Loading Value (kg/day)
30D Qty = Monthly Average Loading Value (kg/day)

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Unless you have already done so, please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,



Dan Messerly
District Staff Engineer
Permits and Enforcement Section
Division of Surface Water

DM/dh