



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 31, 2008

**Re: Perry County**  
Oglebay Norton Industrial Sands  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0IJ00000\*ED  
NPDES Permit No. OH0005541  
Correspondence (IWW/Minor)

Mr. Wayne Dailey  
Oglebay Norton Industrial Sands, Inc.  
Glass Rock Plant  
2446 Glass Rock Road  
Glenford, Ohio 43739

Dear Mr. Dailey:

We have received your self-monitoring reports covering the months of July 2007 through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
<b>September 2007</b>					
009	Total Suspended Solids	30D Conc	30	38.	9/1/2007
<b>January 2008</b>					
009	Total Suspended Solids	30D Conc	30	58.	1/1/2008
009	Total Suspended Solids	1D Conc	45	70.	1/7/2008
009	Total Suspended Solids	1D Conc	45	46.	1/28/2008
<b>February 2008</b>					
009	Total Suspended Solids	30D Conc	30	47.5	2/1/2008
009	Total Suspended Solids	1D Conc	45	69.	2/11/2008
009	pH	1D Conc	6.5	6.43	2/11/2008
009	pH	1D Conc	6.5	6.48	2/25/2008
<b>March 2008</b>					
001	Total Suspended Solids	30D Conc	30	48.	3/1/2008
002	Total Suspended Solids	30D Conc	30	41.5	3/1/2008
009	Total Suspended Solids	30D Conc	30	51.5	3/1/2008
009	Total Suspended Solids	1D Conc	45	62.	3/10/2008
009	pH	1D Conc	6.5	6.21	3/10/2008
001	Total Suspended Solids	1D Conc	45	60.	3/24/2008
002	Total Suspended Solids	1D Conc	45	48.	3/24/2008
009	pH	1D Conc	6.5	6.39	3/24/2008
<b>April 2008</b>					
009	Total Suspended Solids	30D Conc	30	54.	4/1/2008

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
009	Total Suspended Solids	1D Conc	45	54.	4/7/2008
<b>May 2008</b>					
002	Total Suspended Solids	30D Conc	30	274.333	5/1/2008
002	Total Suspended Solids	1D Conc	45	718.	5/5/2008
002	pH	1D Conc	6.5	6.25	5/5/2008
009	pH	1D Conc	6.5	6.25	5/5/2008
002	Total Suspended Solids	1D Conc	45	74.	5/15/2008
<b>June 2008</b>					
001	Total Suspended Solids	30D Conc	30	41.5	6/1/2008
001	Total Suspended Solids	1D Conc	45	62.	6/23/2008
009	Total Suspended Solids	1D Conc	45	46.	6/23/2008

- \*NOTES:** 1D Conc = Daily Average Concentration Value (mg/l)  
 1D Qty = Daily Average Loading Value (kg/day)  
 7D Conc = Weekly Average Concentration Value (mg/l)  
 30D Conc = Monthly Average Concentration Value (mg/l)  
 7D Qty = Weekly Average Loading Value (kg/day)  
 30D Qty = Monthly Average Loading Value (kg/day)

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Unless you have already done so, please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,



for

Dan Messerly  
 District Staff Engineer  
 Permits and Enforcement Section  
 Division of Surface Water

DM/dh