



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

July 31, 2008

Re: Perry County
Tunnel Hill Reclamation
Self-Monitoring Report Violations
Ohio EPA Permit No. 0IN00251*BD
NPDES Permit No. OH0128147
Correspondence (IWW/Minor)

Mr. Rod Deeds, General Manager
Tunnel Hill Reclamation LLC
P.O. Box 625
New Lexington, Ohio 43143

Dear Mr. Deeds:

We have received your self-monitoring reports covering the months of July 2007 through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2007:					
001	Manganese, Total (Mn)	30D Conc	2000	3376.	10/1/2007
001	Manganese, Total (Mn)	1D Conc	4000	5542.	10/27/2007
December 2007:					
001	Manganese, Total (Mn)	30D Conc	2000	3306.	12/1/2007
001	Manganese, Total (Mn)	1D Conc	4000	6291.	12/28/2007


- *NOTES:**
- 1D Conc = Daily Average Concentration Value (mg/l)
 - 1D Qty = Daily Average Loading Value (kg/day)
 - 7D Conc = Weekly Average Concentration Value (mg/l)
 - 30D Conc = Monthly Average Concentration Value (mg/l)
 - 7D Qty = Weekly Average Loading Value (kg/day)
 - 30D Qty = Monthly Average Loading Value (kg/day)

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Unless you have already done so, please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,

A handwritten signature in cursive script, appearing to read "Timothy J. L." with a long horizontal flourish extending to the right. Below the signature, the word "for" is written in a smaller, simpler font.

Dan Messerly
District Staff Engineer
Permits and Enforcement Section
Division of Surface Water

DM/dh