



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

June 12, 2009

Re: Pike County
Village of Beaver
Permit No. OPA00088*CD
WWTP Inspection
Correspondence (PWW)

Mayor and Council
Village of Beaver
P.O. Box 238
Beaver, Ohio 45613

Dear Mayor and Council:

On June 3, 2009, I conducted an inspection of the Village of Beaver wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPT00013*BD. A copy of the inspection report is attached.

During the inspection, I spoke with Greg Wilson, the plant operator, and Stephen Morrison with Woolpert, Inc. about the issue concerning the sand filters. There is definitely an elevation problem between the sand filters and the UV disinfection tank that needs to be addressed. The quick fix will be to replace the filter sand. This will make the sand filters more manageable; however it will not fix the problem. The only way to resolve the elevation issue will be to lower the UV tank or to raise the sand beds.

Enclosed is a copy of my detailed inspection report. Please call me at (740) 380-5268 to discuss the operations of the treatment plant.

Sincerely,

Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure

c: Greg Wilson, Operator
c: Stephen Morrison, Woolpert, Inc.

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PA00088*CD	OH0041505	June 3, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected Village Beaver WWTP 5995 Beaver Pike Beaver, Ohio	Entry Time 10:00 a.m.	Permit Effective Date July 1, 2006
	Exit Time 11:00 a.m.	Permit Expiration Date June 30, 2011


Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Greg Wilson, Operator	(740) 226-2111
Name, Address and Title of Responsible Official	Phone Number
Village of Beaver P.O. Box 238 Beaver, Ohio 45613	(740) 385-5195

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>M</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>N</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)


D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)



 Jack Knapp, Inspector, Ohio EPA, Southeast District Office

6/15/09

 Date



 Tim M. Campbell, Supervisor, Ohio EPA, Southeast District Office

6/16/09

 Date