

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 7, 2011

Re: Pike County
Pike Lake State Park
Permit No. 0PP00024*BD
WWTP Inspection
Correspondence (PWW)

Mr. Matt Lewis, Operator
Pike Lake State Park
1847 Pike Lake Road
Bainbridge, Ohio 45612

Dear Mr. Lewis:

On July 21, 2011, I conducted an inspection of the wastewater treatment plant (WWTP) that serves the Pike Lake State Park. Mickey Brian represented Pike Lake State Park and assisted me during the inspection. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number 0PP00024*BD.

As a part of the inspection, we have reviewed your self-monitoring reports from January 1, 2011 to June 1, 2011 for the Pike Lake State Park WWTP. Our review indicates the plant violated the NPDES permit number 0PP00024*BD several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	18	20.5	2/1/2011
001	00530	Total Suspended Solids	30D Qty	1.37	2.21496	2/1/2011
001	00530	Total Suspended Solids	1D Conc	27	33.	2/3/2011
001	00530	Total Suspended Solids	1D Qty	2.05	4.19556	2/3/2011
001	00530	Total Suspended Solids	30D Qty	1.37	1.86273	3/1/2011
001	00530	Total Suspended Solids	1D Qty	2.05	2.48868	3/3/2011
001	00530	Total Suspended Solids	30D Qty	1.37	2.74683	4/1/2011
001	80082	CBOD 5 day	30D Qty	0.909	1.54082	4/1/2011
001	00530	Total Suspended Solids	1D Qty	2.05	4.82769	4/20/2011
001	80082	CBOD 5 day	1D Qty	1.37	2.68205	4/20/2011
001	00530	Total Suspended Solids	30D Qty	0.909	1.44171	5/1/2011
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.114	.20526	5/1/2011
001	00530	Total Suspended Solids	1D Qty	1.37	1.84632	5/19/2011
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.175	.38978	5/19/2011

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

A copy of the inspection report is attached. Please provide a written response to these comments within 30 days upon receipt describing how the above items will be addressed. If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure: Inspection Report

c: ODNR, Division of Parks and Recreation

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPP00024*BD	OH0037699	July 21, 2011	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Pike Lake State Park 1847 Pike Lake Road Bainbridge, Ohio 45612	11:30 a.m.	March 1, 2006
	Exit Time	Permit Expiration Date
	11:45 a.m.	February 28, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Matt Lewis, Operator	(740) 493-2212
Name, Address and Title of Responsible Official	Phone Number
ODNR Division of Parks and Recreation 2045 Morse Road, C-3 Columbus, Ohio 43229	(614) 265-6511

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N/A</u> Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>N</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


Please see attached letter.



 Jack Knapp, Inspector, Ohio EPA, Southeast District Office

9/7/11

 Date



 Jennifer Witte, Reviewer, Ohio EPA, Southeast District Office

9/8/11

 Date