

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 21, 2011

Re: Pike County
Pike Lake State Park
Self-Monitoring Report Violations
Ohio EPA Permit No. OPP00024*BD
Correspondence (PWW)

Mr. Matt Lewis, Operator
Pike Lake State Park
1847 Pike Lake Road
Bainbridge, Ohio 45612

Dear Mr. Lewis:

We have reviewed your self-monitoring reports covering the months of July through September 2010 for the Pike Lake State Park Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.05	9/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	2.3	3.9	9/9/2010

* D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh