



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 21, 2009

Re: Pike County
Pike Lake State Park
Permit No. 0PP00024*BD
WWTP Inspection
Correspondence (PWW)

Mr. Matt Lewis, Operator
Pike Lake State Park
1847 Pike Lake Road
Bainbridge, Ohio 45612

Dear Mr. Lewis:

On October 2, 2009, I conducted an inspection of the wastewater treatment plant (WWTP) that serves the Pike Lake State Park. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number 0PP00024*BD. A copy of the inspection report is attached.

If there are any questions, please call me at (740) 380-5268.

Sincerely,

Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure

c: ODNR, Division of Parks and Recreation

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PP00024*BD	OH0037699	October 2, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Pike Lake State Park 1847 Pike Lake Road Bainbridge, Ohio 45612	11:30 am	March 1, 2006
	Exit Time	Permit Expiration Date
	12:00 pm	February 28, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Matt Lewis, Operator	(740) 493-2212
Name, Address and Title of Responsible Official	Phone Number
ODNR Division of Parks and Recreation 2045 Morse Road, C-3 Columbus, Ohio 43229	(614) 265-6511

C. AREAS EVALUATED DURING INSPECTION


- | | | |
|-----------------------------------|------------------------------------|----------------------------------|
| <u>S</u> Permit | <u>S</u> Flow Measurement | <u>N/A</u> Pretreatment |
| <u>S</u> Records/Reports | <u>*N</u> Laboratory | <u>S</u> Compliance Schedules |
| <u>S</u> Operations & Maintenance | <u>S</u> Effluent/Receiving Waters | <u>S</u> Self-Monitoring Program |
| <u>S</u> Facility Site Review | <u>S</u> Sludge Storage/Disposal | <u> </u> Other |
| <u>N</u> Collection System | | |

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

*The facility uses a contract laboratory.


The dechlorination tank was installed and has eliminated the residual chlorine violations.



 Jack Knapp, Inspector, Ohio EPA, Southeast District Office

10/29/09

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

10/29/09

 Date