



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 6, 2009

Re: Pike County
Pike Lake State Park
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PP00024*BD
Correspondence (PWW)

Mr. Matt Lewis, Operator
Pike Lake State Park
1847 Pike Lake Road
Bainbridge, Ohio 45612

Dear Mr. Lewis:

We have reviewed your self-monitoring reports covering the months of January through March 2009 for the Old Man's Cave Chalets Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	18	19.	2/1/2009
001	00530	Total Suspended Solids	30D Qty	1.37	9.81859	2/1/2009
001	80082	CBOD 5 day	30D Qty	0.909	1.47235	2/1/2009
001	00530	Total Suspended Solids	1D Conc	27	34.	2/12/2009
001	00530	Total Suspended Solids	1D Qty	2.05	19.5428	2/12/2009
001	80082	CBOD 5 day	1D Qty	1.37	2.87395	2/12/2009
001	00530	Total Suspended Solids	30D Conc	18	45.5	3/1/2009
001	00530	Total Suspended Solids	30D Qty	1.37	5.73304	3/1/2009
001	00530	Total Suspended Solids	1D Conc	27	86.	3/26/2009
001	00530	Total Suspended Solids	1D Qty	2.05	11.3928	3/26/2009

* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh