



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 21, 2010

Re: Pike County
Pike Sanitation
0IN00247*AD
Inspection
Correspondence (IWW)

Mr. Steve Thrasher
Pike Sanitation
12119 State Route 220 E
Waverly, Ohio 45690

Dear Mr. Thrasher:

On May 21, 2010, Tim Campbell, Aaron Wolfe and I met with the owner, Mr. Migyanko, and conducted an inspection of the Pike Sanitation settling ponds. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number 0IN00247*AD. A copy of the inspection report is attached.

As a part of the inspection, we have reviewed your self-monitoring reports from January 1, 2010 to April 1, 2010 for Pike Sanitation. Our review indicates the ponds violated Total Suspended Solids several times. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
002	00530	Total Suspended Solids	30D Conc	30	79.5	2/1/2010
002	00530	Total Suspended Solids	1D Conc	45	79.5	2/23/2010
001	00530	Total Suspended Solids	30D Conc	30	40.5	3/1/2010
002	00530	Total Suspended Solids	30D Conc	30	65.25	3/1/2010
001	00530	Total Suspended Solids	1D Conc	45	72.5	3/19/2010
002	00530	Total Suspended Solids	1D Conc	45	108.	3/19/2010

* 30 D Conc is equal to average monthly concentration limit

During the inspection we discussed the compliance issues related to the "legacy pond" and possible solutions to bring the pond into compliance. These solutions included the use of polymers to help settle out the solids, getting better ground cover, increase the capacity of the existing pond, etc. Please contact me at (740)-380-5268 to discuss these options or to set up a meeting if necessary.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure

c: Steve Rine, DSIWM, SEDO