

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 21, 2011

**Re:** Pike County  
Western Jr./Sr. High School  
Permit No. OPT00049\*DD  
WWTP Inspection  
Correspondence (PWW)

Mr. Joe Morrison, Superintendent  
Western Board of Education  
P.O. Box 130  
Latham, Ohio 45646

Dear Mr. Morrison:

On December 9, 2010, I conducted an inspection of the Western Jr. Sr. High School wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPT00049\*DD. A copy of the inspection report is attached.

As a part of the inspection, we have reviewed your self-monitoring reports from July 1, 2010 to January 1, 2011 for the Western Jr./Sr. High School. Our review indicates the plant violated CBOD5 and NH3. The specific dates and reported values are listed below:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	30D Conc	10	18.	10/1/2010
001	80082	CBOD 5 day	1D Conc	15	18.	10/8/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	3.4	11/1/2010

\* 30 D Conc is equal to average monthly concentration limit

Please provide a written response within 30 days upon receipt of this letter and explain why the violations occurred and explain what will be done to prevent further noncompliance. Enclosed is a copy of my detailed inspection report. If there are any questions, please call me at (740) 380-5268.

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

Enclosure