



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 24, 2010

Re: Ross County
American Legion Post 757
Self-Monitoring Report Violations
Ohio EPA Permit No. OPR00095*AD
Correspondence (PWW)

Mr. Kenny Cottrill, Commander
American Legion Post 757
289 Cooks Hill Road
Chillicothe, Ohio 45601

Dear Mr. Cottrill:

We have received your self-monitoring report covering the months of January through April 2010 for the American Legion Post 757 wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	36.	3/1/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	18.3	3/1/2010
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0171	.02549	3/1/2010
001	80082	CBOD 5 day	30D Conc	10	39.	3/1/2010
001	00530	Total Suspended Solids	1D Conc	18	36.	3/22/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	18.3	3/22/2010
001	80082	CBOD 5 day	1D Conc	15	39.	3/22/2010

*1 D Conc is equal to the maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please submit within **10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations and actions to be taken in the future to maintain compliance has been sent no further action is needed.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Technical Supervisor