



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 9, 2009

**Re:** Ross County  
Blair Mobile Home Park  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PV00020\*AD  
Correspondence (PWW)

Mr. Gary Stites  
P.O. Box 409  
London, Ohio 43140

Dear Mr. Stites:

We have received your self-monitoring report covering the months of January through April 2009 for the Blair MHP's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	16.4	1/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.114	.60069	1/1/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	16.4	1/6/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.171	.60069	1/6/2009
<b>February 2009:</b>						
001	00530	Total Suspended Solids	30D Conc	12	22.	2/1/2009
001	00530	Total Suspended Solids	30D Qty	0.455	.62453	2/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	21.4	2/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.114	.60749	2/1/2009
001	80082	CBOD 5 day	30D Conc	10	13.	2/1/2009
001	00530	Total Suspended Solids	1D Conc	18	22.	2/19/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	21.4	2/19/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.171	.60749	2/19/2009


\*1 D Conc is equal to the maximum daily concentration limit.  
1 D Qty is equal to the maximum daily loading limit.  
30 D Conc is equal to average monthly concentration limit.  
30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Technical Supervisor