



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 24, 2010

**Re: Ross County**  
Carousel Court Mobile Home Park  
Self Monitoring Report Violations  
EPA Permit No. 0PV00008\*FD  
Correspondence (PWW)

Mr. Asa Elsea  
Elsea, Inc.  
P.O. Box 588, 2015 Stone Ridge Drive  
Circleville, Ohio 43113

Dear Mr. Elsea:

We have received your self-monitoring reports covering the months of January through April 2010 for the Carousel Court mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	1D Qty	1.03	1.04466	3/16/2010
<b>April 2010</b>						
001	80082	CBOD 5 day	30D Conc	10	10.5	4/1/2010

\* 1D Qty is equal to the maximum daily loading limit.  
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within 14 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Tom Bouts, Operator