



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 23, 2009

**Re:** Ross County  
Carousel Court Mobile Home Park  
Self Monitoring Report Violations  
EPA Permit No. 0PV00008\*FD  
Correspondence (PWW)

Mr. Asa Elsea  
Elsea, Inc.  
P.O. Box 588  
2015 Stone Ridge Drive  
Circleville, Ohio 43113

Dear Mr. Elsea:

We have received your self-monitoring reports covering the months of September through October 2009 for the Carousel Court mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.85	9/1/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	9/8/2009
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	5.6	9/8/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	9/22/2009
<b>October 2009</b>						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	10/6/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	10/21/2009


\* 1D Conc is equal to the maximum daily concentration limit.  
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within 14 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Tom Bouts, Operator