



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 14, 2009

**Re: Ross County
Carousel Court Mobile Home Park
Self Monitoring Report Violations
EPA Permit No. 0PV00008*ED
Correspondence (PWW)**

Mr. Asa Elsea
Elsea, Inc.
P.O. Box 588
2015 Stone Ridge Drive
Circleville, Ohio 43113

Dear Mr. Elsea:

We have received your self-monitoring reports covering the months of May through August 2009 for the Carousel Court mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	5900.	7/1/2009
001	31616	Fecal Coliform	1D Conc	2000	5900.	7/26/2009
August 2009						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/12/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	1.7	8/25/2009

* 1D Conc is equal to the maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in black ink, appearing to read "Jake Greuey". The signature is written in a cursive style with a large initial "J".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Tom Bouts, Operator